

RFQ 40767

QUESTION AND ANSWERS 03/01/2016

- Are we supposed to supply the two concrete feet with this order, H-14-109618, Rev. 0? >>> **NO**
- Are we supposed to supply the support stand as depicted on H-14-109618, Rev. 0? If so, please provide all the fabrication drawings for the stand. >>> **NO**
- Are we supposed to supply the butterfly valves with this order? >>> **NO**
- Please confirm this is to be a 1200 CFM unit with a 23"x23"x5" moisture separator pad (Ellis & Watts PK 2174-01, Rev. 2 or latest). >>> **NO**

**A 450 CFM Ellis & Watts #PK2704-02 moisture separator pad (13.5" x 13.5" x 5") will be provided as GFM
(this was decided after the MR was already out) >>> an ECN will be forthcoming**